


| | |
|----|----|
| PO | TN |
|----|----|

| | | |
|---------------|------------------|---------------------|
| FOR | TANK LEVEL GAUGE | |
| MOUNTING | SIDE MOUNTING | |
| ENCLOSURE | WEATHER PROOF | |
| MAX. PRESSURE | ATM | kgf/cm ² |
| MAX. TEMP. | 150 | °C |

| NO. | ITEM TO BE PREPARED BY USER | | |
|-----|-----------------------------|----------|---------|
| | DESCRIPTION | MATERIAL | REMARKS |
| 101 | 40A PIPE | | |
| 102 | 40A SOCKET | | |
| 103 | 150A FLANGE | | |
| 104 | 150A GUIDE PIPE | | |

| NO. | ITEM TO BE SUPPLIED BY HITROL | | |
|-----|-------------------------------|---------------------------------|---------|
| | DESCRIPTION | MATERIAL | REMARKS |
| 1 | GAUGE HEAD | ALC | |
| 2 | FLOAT | 316L SS | |
| 3 | SHEAVE ELBOW | □ALC □304 SS | |
| 4 | MEASURING TAPE | 316L SS | |
| 5 | GAUGE SUPPORT | □C.S □304 SS □316L SS | |
| 6 | U-SEAL POT | □ALC+C.S □304 SS □316L SS | |

| TAG NO. | Q'TY | MEASURING RANGE(mm) | SCALE RANGE(mm) | TANK HEIGHT(mm) |
|---------|------|---------------------|-----------------|-----------------|
| | | | | |
| | | | | |
| | | | | |



NOTE
1. GENERAL TOLERANCE IS ±3mm EXCEPT AS NOTED.

| | | | | | | | |
|--|------------|-----------|----------|----------|----------------|------|-----------|
| HITROL CO., LTD. | | | | | SCALE | UNIT | SHEET NO. |
| | | | | | N.S | mm | / |
| TITLE | | | | | PROJECT | | |
| TANK LEVEL GAUGE HLT-1110 | | | | | DRAWING NO. | | |
| | | | | | HLT1110-BBB-01 | | |
| NO. | DATE | REVISION | REV'D BY | CHK'D BY | APP'D BY | | |
| △ | 2024.08.08 | 1ST ISSUE | S H KIM | B S SUNG | J S YANG | | |

This drawing is the property of HITROL and shall not be copied, communicated, or given for tiers except with our written permission.